



CERTIFICATE OF TEST

Page 1 of 1

Scheme No. 10991 Certificate No. Z45596/3

Client Consorzio Cavatori Produttori Porfido Supplier n/a

Date received 12-Jan-09 Date tested 20-Jan-09

Material for test **PORPHYRY** Client ref n/a

Test Method

BSEN 1341:2001 Slabs of natural stone for external paving Annex C BSEN 1342:2001 Setts of natural stone for external paving Annex B

Natural stones - Determination of abrasion resistance - Method A BSEN 14157:2004

12.2 A2 10.8 A3 13.4 A4 11.6 11.8	pecimen	Individual abrasion value	Mean abrasion value
A2 10.8 A3 13.4 A4 11.6 11.8	ference	(mm)	(mm)
A3 13.4 A4 11.6 11.8	A1	12.2	
A4 11.6 11.8	A2	10.8	
	A3	13.4	
A5 11.3	A4	11.6	11.8
	A5	11.3	
46 11.6	A6	11.6	

Remarks

- 1. No surface preparation was carried out
- 2 The test results apply only to the specimens tested

Consorzio Cavatori Produttori Distribution: Authorised by

> Porfido Approved Signatory

Via S. Antonio, 106 PG Shrubsole () Principal Materials Engineer

38041 Albiano (TN)

Italy

Date 22/01/2009

fao Matteo Paolazzi

Jacobs Engineering U.K. Limited, Registered Office: Jacobs House, 427 London Road, Berkshire, Berkshire RG6 IBL, UK. Registered in Engand and Wales

No.259504

Note: Jacobs only accepts responsibility for the accuracy of the results contained in this report. No responsibility can be accepted for the results being representative of the material or items sampled unless sampling has been carried out by the Jacobs Staff. This result cannot be reproduced either in part or in full without the written consent of Jacobs.